



FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

FDN20-4S-4XSGa Busstop Station  
NI/I/2/ABCD /T4A Ta=70°C – NI-1.000  
a = None or -E

Special Condition of Use:

1. Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application including provisions for Division 2 wiring method and access only by the use of a tool.

### Equipment Ratings:

Nonincendive apparatus for use in Class I, Division 2, Groups A, B, C & D; T4A @ Ta = 70°C indoor hazardous (classified) locations, in accordance with control drawing NI-1.000.

### Approved for:

InterlinkBT  
3000 Campus Drive  
Minneapolis, MN 55441



This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600	1998
Class 3611	1999
Class 3810	1989
Including Supplement #1	1995

Original Project ID: 3018300

FM Approval Granted:

4/20/04

Subsequent Revision Reports / Date FM Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Global Technologies LLC

George A. Smith  
Assistant Vice President

4/20/04  
Date