



FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

LTab-Q21-cd-De. EZ-track Q21 Series Linear Displacement Transducers.

NI / 1 / 2 / ABCD / T5 Ta = 70°C

a = Inches of stroke: 4 – 180.

b = Unit of measure: E or M.

c = Output type: LI0, LI1, LU0, LU1, LU2, or LU3.

d = LED: X3 or blank.

e = Cable length in meters.

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C, & D; indoor hazardous (classified) locations
Temperature Class T5 Ta = 70°C

Approved for:

TURCK Inc
3000 Campus Drive
Plymouth, MN, 55441-2656



This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600	1998
Class 3810	1989
Class 3611	1999

Original Project ID: 3014821

FM Approval Granted: October 25, 2002

Subsequent Revision Reports / Date FM Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Global Technologies LLC

David W. Styracula
Technical Team Manager

11/5/02
Date