

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

IM21-14Ex-CDTRi. Rotational Speed Monitor

AIS / I, II, III / 1 / ABCDEFG – IS-1.115; Entity*; I / 0 / Ex [ia] / IIC – IS-1.115; Entity*; NE / I / 2 / ABCD / T5; -25 °C < Ta < +70 °C *For Entity Parameters reference Control Drawing IS-1.115

Special Conditions of Use:

1. Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application, including a tool removable cover.

IM33-FSD-Ex/L. Fire and Smoke Detector Repeater

AIS / I, II, III / 1 / ABCDEFG – IS-1.104; Entity*;
I / 0 / Ex [ia] / IIC – IS-1.104; Entity*;
NI / I / 2 / ABCD / T5; -25 °C < Ta < +70 °C
For Entity Parameters reference Control Drawing IS-1.104

Special Conditions of Use:

1. Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application, including a tool removable cover.

Equipment Ratings:

Associated Apparatus with Intrinsically Safe connections to Class I, II & III, Division 1, Groups A, B, C, D, E, F & G and connection to Class I, Zone 0, Groups IIC, in accordance with the Control Drawing, and Nonincendive for use in Class I, Division 2, Groups A, B, C, and D Hazardous (Classified) Locations

FM Approved for:

Turck Inc. Plymouth, MN



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 213

1987

CSA C22.2 No. 142

1987

Original Project ID: 3036717C

Approval Granted: April 6, 2010

Subsequent Revision Reports / Date Approval Amended

Report Number

Date

Report Number

Date

FM Approvals LLC

Group Manager, Electrical