FM Approvals
Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

BaNbe-Q20L60-cLd-H1151f, BN Series Inclinometer
NI / I / 2 / ABCD / T4 Ta=-30°C to +70°C

a = number of axes: 1 or 2
b = measuring range (deg): 1 thru 360
c = number of outputs: blank or 2
d = output type: i2, U3, U4 or U5
e = orientation: H or V
f = option: /3GD or blank

Special conditions of use:
1 Shall be installed in accordance with control drawing NI-2.413

Equipment Ratings:

Nonincendive for Class I, Division 2, Groups A, B, C and D hazardous (classified) locations

FM Approved for:

Turck Inc
Plymouth, MN United States

FM Approvals

Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3611	2004
Class 3810	2005

Original Project ID: 3044068

Approval Granted: March 23, 2012

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
120403	May 8, 2012		
120517	June 5, 2012		
120611	July 11, 2012		

FM Approvals LLC

J.E. Marquedant
Group Manager, Electrical

4 July 2012
Date